



INTUMESCENT DOOR SEALS

Certificate number: FRPP 454

Certificate only valid if verified on website – www.ifccertification.com

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

Assa Abloy T/A Lorient

Endeavour House
Fairfax Road
Heathfield Industrial Estate
Newton Abbot
Devon
TQ12 6UD

Who manufacture the following intumescent seals:

Lorient Type 617 Sodium Silicate Intumescent Seal (including optional smoke seals)

have satisfied the requirements of the SDP20 Intumescent Door Seal scheme. This includes the testing of products to **BS476: Part 22**, **BS EN1634-1: 2008** and **EN1363-1: 1999** the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve the requisite fire resistance for FD30, FD60, FD90 & FD120 doors are detailed in the schedule FRPP454/S03

Initial Certification: 01 May 2008

Re-issued: 06 October 2023

Valid to: 31 December 2025

Issue Number: 10

Ian Woodhouse
Head of Technical – IFC Certification
Kiwa Ltd

*This certificate consists of 1 page.
Publication of this certificate is permitted.*

CERTIFICATE