FIRE DOOR 11

LVH44 AIR TRANSFER GRILLE FITTED INTO TIMBER FRAME WITH ANGLE FIXINGS

DESCRIPTION


- 1 Timber frame as part of associated doorset framing system
- 2 Lorient intumescent sealant around LVH44 perimeter to a maximum clearance of 10mm
- 3 Lorient LVH44 intumescent air transfer grille
- 4 2mm intumescent liner
- 5 Fixing angle: 20 x 20 x 1mm thick minimum galvanised steel angles fixed to air transfer grille unit with self tapping screws and to timber frame with wood screws

Fixing option 1: 20mm wide angle tabs, central to all four sides or at 200mm maximum centres

Fixing option 2: Full width angles top and bottom only with 200mm fixing centres

CONTENTS

- TOOLS REQUIRED • Angle fixings
- LVH44 air transfer grille
 2mm intumescent liner
 - Self tapping screws
- Cover grille (optional)
- (3.5 x 16mm) • 25mm wood screws
- . Lorient intumescent sealant



FIXING OPTION 1

| - | |
|---|----|
| | П |
| | 1 |
| | 11 |
| | 11 |
| | 1 |
| | 1 |
| | |
| 5 | |
| 1 | Р |
| | |
| | |
| | |
| | |
| | 1 |
| | 1 |
| | |

FIXING OPTION 2

| | ***** | | | | 4.4.4 |
|-------------------|--|------|------|------|--|
| | | | | | |
| | | | | | |
| | | | | | _ |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| ////// | ///////////////////////////////////// | **** | **** | **** | //// //////////////////////////////// |



LVH44 for timber frame with angle fixings

FD30/FD60

Fire Resistance in accordance with BS 476-22:1987

Approval Ref WFRC C121316 (AW4T1)

Max single cell size

Any rectangular shape up to 1200 x 600mm

LVH44 air transfer grilles are supplied 2mm less than the nominal size e.g. a 300mm x 300mm is actually 298mm x 298mm.

INSTALLATION INSTRUCTIONS

- Apply Lorient intumescent liner to the inside faces of the aperture.
- Fix the mounting angles onto the LVH44 air transfer grille using self tapping screws to **one side only.**
- Insert LVH44 into timber frame.
 (Note: air transfer grille does not have to be centrally positioned in the opening).
- Fix the angles to the timber frame with wood screws.
- Apply a bead of Lorient intumescent sealant around the perimeter of LVH44 as shown (note: maximum clearance of 10mm applies).
- Note: Fixings supplied by others.

